



PROVINCIAL GOVERNMENT OF DAVAO DE ORO

Cabidanan, Nabunturan, Davao de Oro

TECHNICAL SPECIFICATIONS FORM

Purchase Request Number: 24-2586

Bid Number: B-24-0136
Date: 05/31/2024
Page: 1 of 1

ITEM NO.	QTY.	UNIT OF ISSUE	DESCRIPTION	APPROVED BUDGET		BID PRICES	
				Unit Price	Total Amount	Unit Price	Total Amount
1	270858.0	lot	<p>Installation Of Transformer</p> <p>Improvement of De Oro Bahay Pangarap Facility</p> <p>Transformer and Accessories: *Transformer, Pole Type, Conventional, Amorphous #35.7KVA, Cu-Cu Winding - 1 unit Bracket, Mounting for cutout and arrester - 1 pc Bracket, Mounting for Transformer Pole - 1 set Clamp, Hot Line #2-#2/0 ACSR main to #2-#2/0 - 1pc Cut-out Arrester and Combination, Polymer Assy. - 1 set Link, Fuse, Universal, Bottom Head, type K, 6 Amperes - 1 pc Stirrup - 1 pc Connector, Compression, YHO 200, #1/0-#2/0 ACSR Run to #6-#2 - 5 pcs. Clevis Secondary Swinging without Spool - 1 pc Spool Insulator, 1 3/4" - 1 pc Bolt, eye 5/8" X 10 with nut and washer - 1 pc Clamp Loop Deadend #2/0-4/0 ACSR - 4 pcs. #1/0 Polytheline Drop Wire - 60 mtrs.</p> <p>TERMS AND CONDITIONS: 1.) Supply and Installation of Transformer commence only upon, receipt of Notice to Proceed. 2.) Scope of Works to be undertaken shall conform with the Plans and Specification. 3.) All equipment needed in the implementation shall be provided by the Supplier. 4.) Calendar days to complete is 15 days. 5.) Submit the transformer Testing Result with Noted "PASSED" to the NORDECO standard.</p>	1.00	270,858.00		
TOTAL/LOT					270,858.00		

Purpose: Improvement of De Oro Bahay Pangarap Facility (Installation of Transformer)
Delivery: JOB SITE
Period of Delivery: 15 DAYS